



LG&E Energy ~~Corp~~ LLC*
220 West Main Street (40202)
P.O. Box 32030
Louisville, Kentucky 40232

March 1, 2004

Mr. Thomas M. Dorman
Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, Kentucky 40601

RECEIVED

MAR 01 2004

PUBLIC SERVICE
COMMISSION

Dear Mr. Dorman:

Re: Case No. 99-441 **Sample Meter Testing Pilot Plan**

The PSC Order in Case Number 99-441 allowed for a new sample-testing plan for participating electric utilities. This order required these same utilities to submit an annual report to the Commission.

Pursuant to the October 25, 2000 Revised Amended Sample Meter Testing Pilot Plan, Appendix A, Section I (4) and Appendix A, Section II (D)(3)(b), **Louisville Gas and Electric Company** submits the following:

The Certified Test Results of all new meters received
(Attachment A)

2002 Statistical Sampling Test Results and Summary
(Attachment B)

The eight meters denoted in the Summary as "Not Tested" were incorrectly noted as available for testing. This programming error allowed for six 'Does not exist' meters and two 'Previous failed lot' meters to be listed in the 2003 Sample.

If you have any questions please do not hesitate to contact me.

Sincerely,

Marty J. Reinert
Regulatory Analyst II
Regulatory Affairs

Attachments

Cc: Mr. Dennis Hildenbrand

LG&E

2003 SAMPLE

ELECTRIC METER SUMMARY

SAMPLE

In-Service Population	359,284	Divided into 55 Lots
Sample Quantity	3,352	
Meters Tested	3,330	
Meters Not Tested	22	
Failed Lots	0	
Failed Lot Meters	0	

DETAIL OF METERS NOT TESTED

Not Tested

425614	D4	Does not exist
226849	I50	Does not exist
320256	I60-2	Does not exist
511940	I70-5	Does not exist
309893	J3	Does not exist
315753	J3	Does not exist
152646	I30	Previous Failed Lot
174338	I30	Previous Failed Lot

Lost/Stolen

505526	D5	Not located, presumed lost
508807	D5	Not located, presumed lost
294873	I60	Not located, presumed lost
609963	J5-4	Not located, presumed lost
671978	MSII-5	Not located, presumed lost

Open Potential Coil

313388	I60
368520	I70
382702	I70
572688	I70-7
530949	J5

Damaged

292329	I60	
301493	J3	Vandalized
694371	J5-6	Fire

Tamper

478997	I70-4	Open potential clip
--------	-------	---------------------